




# AGA CERTIFIED PRODUCT

JAS-ANZ



www.jas-anz.org/register

Certificate Holder: **BROMIC PTY LTD**

ABN/ACN No. (if applicable): **001 648 979**

Manufacturer: **LOXEAL ENGINEERING ADHESIVES - ITALY**

Agent (if applicable): **N/A**

Type of Component: **THREAD SEALANT  
CLASS III MWP 2000kPa  
Temperature Range: -10°C to 150°C**

Model No. & Description: **LOXEAL  
58-11**  
*(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)*

Relevant Standard(s): **AS 4623 - 2008**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Reviewing Officer

Certificate Authorised

Certificate first issued: **15 September 1993**

Certificate No: **5048**

This copy valid from: **24 September 2010**

Refer specification issue: **03**