



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5146AT0263

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	LOXEAL s.r.l. Via Marconato, 2, I-20031 Cesano Maderno (MI)
Distributor <i>Vertreiber</i>	LOXEAL s.r.l. Via Marconato, 2, I-20031 Cesano Maderno (MI)
Product Category <i>Produktart</i>	greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)
Product Description <i>Produktbezeichnung</i>	Anaerobic sealing material, not permissible for use in the gas installation according to DVGW-TRGI 2008
Model <i>Modell</i>	LOXEAL 15-36
Test Reports <i>Prüfberichte</i>	type testing: 13/155/5146/1 from 30.07.2013 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 751-1 (01.05.1997)

Date of Expiry / File No. 31.08.2018 / 13-0490-GNV
Ablaufdatum / Aktenzeichen

16.08.2013 Rie A.1/2

Date, issued by: Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
LOXEAL 15-36	class: H	for diameters > DN 10 to DN 50

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

suitable for: metallic threaded joints for use on rough threads
not allowed for use in the gas installation according to DVGW-TRGI 2008