



**CERT**

# DIN-DVGW type examination certificate

## DIN-DVGW-Baumusterprüfzertifikat

**NG-5146AU0039**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	LOXEAL S.r.l. Via G. Marconato, 2, I-20811 Cesano Maderno (MI)
<b>Distributor</b> <i>Vertreiber</i>	LOXEAL S.r.l. Via G. Marconato, 2, I-20811 Cesano Maderno (MI)
<b>Product Category</b> <i>Produktart</i>	Greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)
<b>Product description</b> <i>Produktbezeichnung</i>	Anaerobic sealing material for metallic threaded joints, not permissible for use in the gas installation according to DVGW-TRGI 2018
<b>Model</b> <i>Modell</i>	LOXEAL® 58-11
<b>Test reports</b> <i>Prüfberichte</i>	Type testing: 14/086/5146/2 from 18.09.2014 (EBI) Laboratory control test: 21-00293-KP3 from 03.04.2023 (EBI)
<b>Test basis</b> <i>Prüfgrundlagen</i>	DIN EN 751-1 (01.05.1997)

**Date of Expiry / File No.** 28.02.2029 / 24-0032-GNV  
**Ablaufdatum / Aktenzeichen**



16.01.2024 Stö A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

*J.A. W. T. C.*



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-01

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

<b>Type</b> <i>Typ</i>	<b>Technical Data</b> <i>Technische Daten</i>	<b>Remarks</b> <i>Bemerkungen</i>
LOXEAL® 58-11	Class: H	for nominal diameters > DN 10 up to DN 50